



GOVERNMENT OF TRIPURA  
DIRECTORATE OF FIRE & EMERGENCY  
SERVICES  
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSCTFES/2023/00049

Dated: 08/06/2023

**Sub: FIRE SAFETY CERTIFICATE**

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Asis Kumar Debnath			
Name of Owner with Plot details:-	<b>S. No.</b>	<b>Owner Name and Address</b>		
	1.	দং ভক্তি বেদান্ত এডুকেশন এন্ড সাইন্টিফিক রিসার্চ ট্রাস্ট এর পক্ষে সেক্রেটারী- সাং-ভোলানন্দপল্লী পোঃ কাঠাল বাগান		
	<b>S. No.</b>	<b>Plot No</b>	<b>Total Area</b>	<b>Classification</b>
	1.	12293	2.66	বিদ্যালয়
Name of the Property/ Organization/ Commercial establishment	Sri Krishna Mission School			
Address of the Building/ Premises:-	Area Name Bholananda Palli, Ward No.2, Agartala Municipal Corporation, Post Office Kunjaban S.O - 799006, West Tripura District, Tripura.			

**Director,**  
**Fire & Emergency Services,**  
Or Authorized Signatory  
Tripura : Agartala

This certificate will expire on 08/06/2026

**Conditions for the Validity of Fire Safety Certificate (NOC).**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

The Fire NOC is issued for only the portion of mentioned area that is being occupied by "Sri Krishna Mission School" (788.8 sqm. covered area of RCC G+2 storied [Bishnupriya Block] building) Applicants Name- Shri Asis Kumar Debnath. No way shall it be applicable for the other portions.

Digitally signed by Debjani Deb Sarkar  
Date:2023.06.08 01:26:52 +05:30



GOVERNMENT OF TRIPURA  
DIRECTORATE OF FIRE & EMERGENCY  
SERVICES  
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSCTFES/2023/00048

Dated: 08/06/2023

**Sub: FIRE SAFETY CERTIFICATE**

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Asis Kumar Debnath			
Name of Owner with Plot details:-	<b>S. No.</b>	<b>Owner Name and Address</b>		
	1.	দং ভক্তি বেদান্ত এডুকেশন এন্ড সাইন্টিফিক রিসার্চ ট্রাস্ট এর পক্ষে সেক্রেটারী- সাং-ভোলানন্দপল্লী পোঃ কাঠাল বাগান		
	<b>S. No.</b>	<b>Plot No</b>	<b>Total Area</b>	<b>Classification</b>
	1.	12293	2.66	বিদ্যালয়
Name of the Property/ Organization/ Commercial establishment	Sri Krishna Mission School			
Address of the Building/ Premises:-	Area Name Bholananda Palli, Ward No.2, Agartala Municipal Corporation, Post Office Kunjaban S.O - 799006, West Tripura District, Tripura.			

**Director,**  
**Fire & Emergency Services,**  
Or Authorized Signatory  
Tripura : Agartala

This certificate will expire on 08/06/2026



**Conditions for the Validity of Fire Safety Certificate (NOC).**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

The Fire NOC is issued for only the portion of mentioned area that is being occupied by "Sri Krishna Mission School" (773.8 sqm. covered area of RCC G+2 storied [Damodar Block] building) Applicants Name- Shri Asis Kumar Debnath. No way shall it be applicable for the other portions.

Digitally signed by Debjani Deb Sarkar  
Date:2023.06.08 01:24:21 +05:30